

To: Civian, Frederick (DEP)[frederick.civian@state.ma.us]
From: Tedder, Newton
Sent: Fri 5/12/2017 8:46:34 PM
Subject: Re: dry weather sampling

For number 1 the answer is actually yes and no. they get out of the initial screening and can begin investigations of the system. once the investigations are all done they have to sample each outfall again within 5 years in accordance with part 2.3.4.10

for number 2 - yes they have to resample. however for outfalls that had flow during dry weather and they have the data they only need to collect a chlorine sample. for other outfalls that they find flowing that were not sampled in the past they need to do the entire suite

Newt
Phone: (617) 918-1038

All drains lead to the ocean

From: Civian, Frederick (DEP) <frederick.civian@state.ma.us>
Sent: Friday, May 12, 2017 4:08:12 PM
To: Tedder, Newton
Subject: dry weather sampling

(not really a) hypothetical . .

1 - If I did dry weather sampling for all the parameters listed in the new MS4 at all outfalls in 2010, do I have to do it again?

2 - If I did all but chlorine, do I have to do them all again?

For #1

My answer is “no” you already did it once so you are done now

(alternative answer: “yes” - since flows to outfalls can change, the permit requires this new round of such sampling once during the permit term (end of year 3)

For #2

My answer is “yes” you have to go back and look for chlorine

Frederick Civian

MassDEP Stormwater Coordinator

617-292-5821

<http://www.mass.gov/eea/agencies/massdep/water/wastewater/stormwater.html>

